

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0694:141 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Fire Control Instruments, 301 2nd Avenue, Waltham, MA 02451-1133
Contact: Anthony J. Shalna (781) 487-0088

DESIGN: Models FC-ID and FCID-X control units. Automatic or manual; non-coded; inherently power-limited; local, auxiliary, remote station service, proprietary (protected) premises unit and central station services; waterflow alarm service. Refer to listee's data sheet for detailed product description and operational considerations. System components:

| | |
|--------------|--------------------------------|
| CA-I | System cabinet |
| PSM | Power Supply Module |
| MCM | Microcontroller Module |
| DTM | Device Termination Module |
| DLM | Dual Loop Module |
| KDM-4 + /40+ | Keyboard Display Module |
| RIM-U | Remote Identification Module |
| CPM | Control Point Module |
| SLM | Sub-loop Module |
| EOL-E | Electron End-of-Line |
| KDM-4R/40R | Remote Keyboard Display Module |
| RDE-R/B | Remote Display Enclosure |

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices.

*This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. Refer to manufacturer's Installation Manual for details.

*Corrected 09-03-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 23, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO, Supervising Deputy
Program Manager**